



## LYONS FIRE PROTECTION DISTRICT

March 7, 2019

To: Town of Lyons,  
Ref- 231 Park Street

To whom it may Concern,

I was contacted by owner Steve McCain of 231 Park street reference his new home. It was brought to my attention that the possibility of deleting the man door on the west side of the home has come up during discussion. We do not agree with this as; the original plan had this door specifically designed and installed as it is also a door used for egress in the event of a fire. I feel that this door must remain in place to serve as an egress / exit path and doorway regarding life safety.

If you have any questions regarding this permit please contact me,

Sincerely,

A handwritten signature in black ink, appearing to read 'J.J. Hoffman', with a long horizontal flourish extending to the right.

J.J. Hoffman  
Fire Chief

